

ASHRAE HQ - Commissioning Inquiries Log

2/6/2019

	Question	Response
	Questions Submitted via Email	
1	The OPR part 4.1 and 9.6 references blower door testing. Confirm the blower door tests and thermography (pre and post) will be performed by others. Although not mentioned in the RFP, this is sometimes assumed to be in the commissioning scope of work.	The blower door testing is not in the commissioning scope.
2	The RFP, Page 4, Part 4 - Equipment and Systems to Commission: Please confirm that there will be no envelope commissioning other than the solar shading devices. The OPR mentions possible envelope remediation and tightening.	Envelope commissioning is not included in the commissioning scope.
3	Given the EUI / NZE goals of the project, is commissioning/testing of the building envelope to be part of the scope? Note that for LEED certification, envelope commissioning is an option under Enhanced Commissioning.	LEED certification is not certain and scope of envelope remediation is unknown. Envelope commissioning is not included in the commissioning scope.
4	Are there any renewable energy sources planned to be installed as part of the base project that should be included in the commissioning scope? Note that for LEED certification all renewable energy sources would need to be commissioned.	LEED certification is not certain at this time. Renewable energy source commissioning is not included in the commissioning scope.