

## ERRATA NOTES

### for *Principles of HVAC (Howell et al. 2001)* and *Solutions Manual*

**p. 2.30, Equation (2-50).** Add the subscript “*in*” after the first set of parentheses, and the subscript “*out*” after the second set.

**p. 3.3, 2nd column.** The first line of the first equation should be “ $W_1 = 0.622p_w/(p_1 - p_{w_1})$ .”

**p. 4.17, Table 4-8.** The entry under Missouri for “Kansas” should be for “Kansas City.”

**pp. 5.28-5.29, Examples 5-3 and 5-4.** Please correct the table references for these components:

In Example 5-3,		
Outside air	0.17	(Table 5-12)
Brick, 4-in. face	0.44	(Table 5-15)
Inside air	0.68	(Table 5-12)

In Example 5-4,		
Inside air	0.61	(Table 5-12)
Outside air	0.17	(Table 5-12)

**p. 5.42, Table 5-16.** The units for the table should be W/(m<sup>2</sup>·K).

**p. 7.9, 2nd column.** In the first and third equations, “*u*” should be “*U*.”

**p. 7.32, Table 7-29 (Concluded).** Please use the values in the corrected table on page 2.

**p. 7.33, Table 7-30.** The U-factor for Roof 7 should be 0.069.

**p. 7.35, Table 7-32.** Please correct the following table references:

External Cooling Load, roofs, walls, and conductance through glass,	
CLTD	= cooling load temperature difference, roof, wall, or glass, Tables 7-33, 7-35, and 7-38
Internal Cooling Load, people,	
CLF	= cooling load factor, by hour of occupancy, Table 7-41
Internal Cooling Load, lights,	
CLF	= cooling load factor, by hour of occupancy, Table 7-42
Internal Cooling Load, power,	
CLF	= cooling load factor, by hour of occupancy, Table 7-41
Internal Cooling Load, appliances,	
$q_{input}$	= rated energy input from appliances—Tables 7-17 through 7-27
CLF	= cooling load factor, by scheduled hours and hooded or not; Tables 7-41 and 7-43

**p. 7.82, Problem 7.37.** “Tights” should be “lights.”

**p. 8.11, Table 8-2.** The heating degree-day value for Charleston City, South Carolina, at 50°F base should be 412.

**p. 8.13, Example 8-2.** Please replace the solution equations with the following:

Table 8-2: Cooling degree-days = 2098

(a) Using cooling degree method,

$$\begin{aligned} \text{Cooling} &= [36,500/(98 - 78)] \times 2098 \times 24 \\ &= 91,900,000 \text{ Btu} \end{aligned}$$

$$E_C = (91,900,000)/(1000 \times 11.5) = 7,900 \text{ kWh}$$

(b) Cost = 7,900 kWh × \$0.069/kWh = \$551

**p. 11.17, Problem 11.10.** The air system is operating at 4 in. of water total pressure, and the water system has a pump head of 40 ft.

**p. 12.13, 2nd column.** The cold deck temperature should be 58°F.

**p. 12.14.** The 5th equation for Zone 1, Summer, should have a  $Q$ , not a  $V$ . In the 6th equation for System No. 2, “15960” should be “15,860.”

**p. 12.15.** In the last equation for System No. 2, “0.00132” should be “0.0032.” In the last equation for System No. 3., “800” should be “1800.”

**Solutions Manual, Example 3.26.** The units in the second line of (a) should be lb/h.

**Solutions Manual, Example 7.11.** The solution for the pendant lamps should be

$$q = (\text{wattage})(\text{use factor})(3.413) = (50)(4)(40)(1)(3.413) = 27,304 \text{ Btu/h}$$

**Table 7-29 Wall Conduction Time Series (CTS), Layers, U-Factors, Mass and Thermal Capacity (Concluded)**

(Table 20, Chapter 29, 2001 ASHRAE Handbook—Fundamentals)

Wall Number =	CONCRETE BLOCK WALL						PRECAST AND CAST-IN-PLACE CONCRETE WALLS									
	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	
<b>U-factor, Btu/h·ft<sup>2</sup>·°F</b>	0.067	0.059	0.073	0.186	0.147	0.121	0.118	0.074	0.076	0.115	0.068	0.082	0.076	0.047	0.550	
<b>Total R</b>	14.8	16.9	13.7	5.4	6.8	8.2	8.4	13.6	13.1	8.7	14.7	12.2	13.1	21.4	1.8	
<b>Mass, lb/ft<sup>2</sup></b>	22.3	22.3	46.0	19.3	21.9	34.6	29.5	29.6	53.8	59.8	56.3	100.0	96.3	143.2	140.0	
<b>Thermal Capacity, Btu/ft<sup>2</sup>·°F</b>	4.8	4.8	10.0	4.1	4.7	7.4	6.1	6.1	10.8	12.1	11.4	21.6	20.8	30.9	30.1	
<b>Hour</b>	<b>Conduction Time Factors, %</b>															
0	0	1	0	1	0	1	1	0	1	2	1	3	1	2	1	
1	4	1	2	11	3	1	10	8	1	2	2	3	2	2	2	
2	13	5	8	21	12	2	20	18	3	3	3	4	5	3	4	
3	16	9	12	20	16	5	18	18	6	5	6	5	8	3	7	
4	14	11	12	15	15	7	14	14	8	6	7	6	9	5	8	
5	11	10	11	10	12	9	10	11	9	6	8	6	9	5	8	
6	9	9	9	7	10	9	7	8	9	6	8	6	8	6	8	
7	7	8	8	5	8	8	5	6	9	6	7	5	7	6	8	
8	6	7	7	3	6	8	4	4	8	6	7	5	6	6	7	
9	4	6	6	2	4	7	3	3	7	6	6	5	6	6	6	
10	3	5	5	2	3	6	2	2	7	5	6	5	5	6	6	
11	3	4	4	1	3	6	2	2	6	5	5	5	5	5	5	
12	2	4	3	1	2	5	1	2	5	5	5	4	4	5	4	
13	2	3	2	1	2	4	1	1	4	5	4	4	4	5	4	
14	2	3	2	0	1	4	1	1	4	4	4	4	3	4	4	
15	1	3	2	0	1	3	1	1	3	4	3	4	3	4	3	
16	1	2	1	0	1	3	0	1	2	4	3	4	3	4	3	
17	1	2	1	0	1	2	0	0	2	3	3	4	2	4	3	
18	1	2	1	0	0	2	0	0	1	3	2	4	2	4	2	
19	0	1	1	0	0	2	0	0	1	3	2	3	2	3	2	
20	0	1	1	0	0	2	0	0	1	3	2	3	2	3	2	
21	0	1	1	0	0	2	0	0	1	3	2	3	2	3	1	
22	0	1	1	0	0	1	0	0	1	3	2	3	1	3	1	
23	0	1	0	0	0	1	0	0	1	2	2	2	1	3	1	
<b>Total Percentage</b>	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	
<b>Layer ID from outside to inside (see Table 22)</b>	F01 M03 I04 G01 F02 —	F01 M08 I04 G01 F02 —	F01 F07 M05 I04 G01 F02	F01 M08 F02 — — —	F01 M08 F04 G01 F02 —	F01 M09 F04 G01 F02 —	F01 M11 I01 F04 G01 F02 F02	F01 M11 I04 G01 — — —	F01 M11 I02 M11 G01 F02 —	F01 F06 I01 M13 G01 F02 F02	F01 M13 I04 G01 M15 F02 —	F01 F06 I02 M15 G01 F02 F02	F01 M15 I04 G01 F02 — —	F01 M16 I05 G01 F02 — —	F01 M16 I05 G01 F02 — —	F01 M16 I05 G01 F02 — —

**Wall Number Descriptions**

- |                                                                        |                                                                      |
|------------------------------------------------------------------------|----------------------------------------------------------------------|
| 21. 8 in. LW CMU, R-11 batt insulation, gyp board                      | 29. 4 in. LW concrete, R-10 board insulation, 4 in. LW concrete      |
| 22. 8 in. LW CMU with fill insulation, R-11 batt insulation, gyp board | 30. EIFS finish, R-5 insulation board, 8 in. LW concrete, gyp board  |
| 23. 1 in. stucco, 8 in. HW CMU, R-11 batt insulation, gyp board        | 31. 8 in. LW concrete, R-11 batt insulation, gyp board               |
| 24. 8 in. LW CMU with fill insulation                                  | 32. EIFS finish, R-10 insulation board, 8 in. HW concrete, gyp board |
| 25. 8 in. LW CMU with fill insulation, gyp board                       | 33. 8 in. HW concrete, R-11 batt insulation, gyp board               |
| 26. 12 in. LW CMU with fill insulation, gyp board                      | 34. 12 in. HW concrete, R-19 batt insulation, gyp board              |
| 27. 4 in. LW concrete, R-5 board insulation, gyp board                 | 35. 12 in. HW concrete                                               |
| 28. 4 in. LW concrete, R-11 batt insulation, gyp board                 |                                                                      |