

# INDEX

## A

absorption equipment 489–90, 532  
absorption refrigeration 22, 49, 53, 509, 527, 584  
adiabatic  
  mixing 36, 38, 69, 70  
  saturation process 30  
adjacent unconditioned spaces 140  
AFUE 297, 304, 547  
air  
  cleaners 5, 399, 492, 494, 496–97  
  contaminants 2, 145  
  distribution 81, 154, 157, 197, 292, 351, 355–58, 380, 397, 399, 403, 405, 418, 454, 455, 584, 587  
  handling equipment 292, 407, 481, 488  
  leakage 89, 146–48, 150–52, 159, 173, 191, 194–96, 210, 219, 249, 498  
  moving 8, 70  
  quality 1, 5, 8, 74, 84, 146–47, 151, 153–54, 196, 393, 399, 419, 492  
  ventilation 73, 136, 156  
air conditioner 4–5, 48, 74, 78, 298, 308, 351, 382, 410–11, 415, 421, 453, 455–56, 467, 481–83, 525, 587–89  
air distribution 81, 154, 157, 197, 292, 351, 355, 356, 358, 380, 397, 399, 403, 405, 418, 454, 455, 584, 587  
air leakage 147, 163, 179, 507  
air washer 4, 318, 382, 485, 487–88, 490, 492, 505, 580, 587  
air-and-water systems 396  
air-conditioning  
  components 395  
  equipment 1, 5, 148, 173, 408, 453  
  system 1–2, 4, 7–8, 51, 67, 81, 140, 158, 191, 212, 219, 223, 249, 250, 306, 311, 316, 318, 354, 356, 365, 379, 393, 395, 398, 400, 405–407, 412, 419, 453, 483, 515, 572, 586  
air-heated floor 462–63  
air-volume equation 72  
antifreeze 431  
antifreeze solution 402, 450, 469  
appliances 259  
aqua-ammonia 22  
aqua-ammonia enthalpy-concentration diagram 22, 26, 63  
ASHRAE  
  history 2–4  
  Standard 34 527, 529  
  Standard 51 349, 369  
  Standard 52 402  
  Standard 55 81–82, 84–86, 193, 140, 202  
  Standard 62 146–47, 151, 153–56, 191, 196, 393, 399, 404–405, 408, 419–20, 589

Standard 90.1 6, 8, 140, 235, 240–42, 403, 417  
Standard 103 547  
Standard 169 121  
ASHRAE atmospheric data 36, 55

## B

basements, heat loss from 136, 194, 196, 202–203, 209  
bin method 292, 295, 304, 306  
boiler 1–5, 219, 233, 270, 292, 304, 362–64, 367–68, 380, 382, 385, 405–10, 427, 431–34, 441, 443, 446–47, 449–51, 459, 467, 471–74, 478, 492, 498, 544–45, 550–52, 554, 556, 580, 582, 584, 586, 589  
buffer spaces 191, 194, 196, 201, 204, 215  
building use 291  
burner 243, 245, 288–89, 382, 472, 542–45, 547–48, 550, 586

## C

capillary tube 456, 482, 525–26  
capital recovery factor 388, 391  
Carrier, Willis 4–5, 416  
chiller 1–2, 5, 7–8, 136, 158, 219, 292–93, 304, 380–82, 386, 389, 390–91, 405–407, 409, 423, 427, 429, 431, 434, 437, 439, 441, 444–47, 450, 452–53, 467, 469, 472, 477, 478, 498, 517, 525, 532, 534, 567, 571, 580, 583–84, 587  
clothing insulation value 84  
coefficient 145, 170, 219, 223, 225–27, 230–31, 258, 277  
  heat transfer 8, 141, 158, 174, 201, 220, 223, 225, 251, 258, 268, 432–43, 505, 520, 526–28, 560–61, 564–65, 568–69, 571, 573–74  
  shading 198, 230, 589  
  thermal resistance 159, 161, 174–75, 204, 582  
cogeneration 6, 292, 405, 467, 472, 478  
coil  
  application range 483  
  construction 481–82  
  cooling 7, 36, 71–72, 74, 79, 140, 219–20, 237, 248, 249–95, 316, 364, 385, 396–97, 400, 402, 409–11, 417, 420, 423, 426–29, 433, 447, 449, 452, 455, 457, 462, 481–84, 488, 492, 498, 504, 506, 547–48, 567, 569, 574, 586  
  energy recovery loop 499–501  
  heating 74, 318, 397, 402, 405, 410–11, 417, 419–21, 427–28, 433, 443–44, 449, 456, 459, 463, 481, 486–87, 492, 498, 505, 545, 556, 559, 567, 575  
combustion 2–3, 29, 39, 154, 242, 381, 406, 408, 431, 433, 472, 496, 541–44, 545, 547–48, 550–51, 555

comfort condition 3, 85, 88, 393, 417, 445, 455, 554  
comfort zone 85–86, 143  
commercial furnace 547, 548  
compressor  
  centrifugal 405–406, 477, 509, 517, 526, 583  
  reciprocating 3–4, 382, 406, 509–11, 584  
  rotary 5, 406, 511–13, 517  
  screw 513–15, 526  
conceptualizing 7  
condenser 45–47, 49–50, 52–3, 293, 364, 368, 380, 382, 406–408, 410, 423, 434, 453, 455–59, 467, 469, 471–72, 475–77, 482, 487, 501, 504–505, 509, 519–22, 525–26, 532–33, 536, 540, 567, 571–72, 575, 583–84  
conduction time series 250–54, 260, 264  
conservation of mass 13, 42, 67, 560  
continuity equation 13, 69  
convective and radiant percentages 243, 249  
convector 3, 362–63, 367, 410, 421–22, 432–33, 443, 552–54  
cooler  
  liquid 525, 527–28  
cooling coil 7, 36, 71, 74, 79, 140, 219, 220, 237, 249  
cooling load 1–2, 72, 136, 145, 159, 169, 174, 191–94, 197–200, 206, 208–209, 212–13, 217, 219, 220–23, 225, 233, 236–37, 239, 242, 248–49, 251, 253, 257, 259–61, 263–71, 294, 296, 298, 304, 306, 308, 310, 364, 393–96, 398, 410, 412, 422, 423, 429, 433, 454, 457, 461, 469, 470, 474, 477, 478, 505–506, 519, 547–48, 586, 588, 589  
  appliances 241–42  
  temperature difference 222, 251, 304  
  methodology 197  
cooling method 191–92  
  cooling method, degree-day 296, 298, 304  
cooling tower 292, 364, 380, 382, 385, 389, 406–408, 416, 432, 459, 467, 470, 477, 487–88, 504, 509, 522, 533, 535–36, 570–71, 580, 583–84, 589  
costs 2, 6–7, 292–94, 298, 306, 308, 310, 318–19, 361, 379–91, 396, 400, 405, 407–408, 416, 436, 440, 443, 449, 461, 470–71, 473, 478, 497, 499, 504, 547, 556

## D

damper 7, 72, 74, 148, 196, 292, 294, 297, 318–20, 338, 340–41, 354–55, 365–68, 380, 382, 397, 400–403, 405, 407, 410, 417, 419–20, 449, 467, 473, 481, 486, 492, 498, 504, 507, 518, 544, 547

degree-day 89  
data for various locations 137–39, 304  
energy estimating methods 121, 291, 295–98, 306, 310  
variable-base heating 298  
dehumidification 72, 76, 80, 88–89, 121, 136, 145–47, 156, 191, 199, 393, 402, 410–11, 420, 433–44, 457, 461–62, 471, 483, 488–90  
desiccant 136, 489–99  
design  
criteria for various occupancies 86–87, 136, 381, 399  
hydronic system 364, 431–32, 436–38, 440–42, 447, 450–51, 462, 552, 556  
design condition  
metabolic rate 83–84  
design conditions 1–2, 5, 71, 81, 83, 87, 89, 121–36, 140, 142, 148, 152, 156, 175, 193–94, 201–202, 204–205, 207, 223, 264, 267, 292–93, 298, 309, 393, 404, 423, 436, 443, 475, 488, 501–502, 506, 547, 584, 587–89  
indoor 81, 173, 202, 223, 259  
moisture and humidity 88  
outdoor 71, 89, 156, 193, 223, 423  
design problems 583  
diffuser 4, 219, 230, 311, 345–47, 356, 358, 363, 367, 380, 382, 395, 403, 418, 461–462, 517, 519, 580, 586  
door 148, 150, 152, 153, 161, 172, 187, 197, 204, 208, 552  
dry-bulb temperature 136, 475, 487, 497  
dual-duct system 5, 417  
duct  
circular equivalent of rectangular 313, 371  
design procedures 318–19  
design velocities 318  
fitting loss coefficient 316, 319, 321  
friction chart 313, 317  
system characteristics 354  
ductwork 72, 249, 292, 312, 316, 319, 345, 346, 349, 351, 353–54, 382, 397, 399, 401–404, 408–409, 416–17, 421, 453, 456, 491, 497, 544–45, 548

## E

economics 7, 379, 383–84, 396, 400, 405, 434, 436, 440, 443, 445, 497  
economizer 146, 294, 295, 400–401, 416, 455, 473, 475, 504–505, 532, 567  
efficiency  
steady-state 296, 547  
utilization 297, 547  
electric heating 5, 306, 406, 419, 461, 463, 464, 481, 486, 551, 553, 554  
energy 385  
building use 5, 7, 291, 293  
costs 6–7, 293, 298, 306, 386, 390, 396, 405, 436, 471, 504  
forms 5, 291  
recovery 206, 415, 481, 497–501, 507, 589  
required for humidification 547  
transient 38

energy estimating  
variable-base, degree-day method 291, 297–98, 304  
enthalpy 12, 14, 17–19, 22, 24–25, 28, 31–33, 36, 41, 44–45, 48, 56–57, 59–60, 62–64, 67, 68–69, 71, 89, 121, 135, 136, 193, 206, 294, 403, 433, 472, 497, 502, 504, 519, 521, 567, 577, 581  
enthalpy-concentration diagram 22, 26, 28, 63  
entropy 11–12, 14, 17–19, 22, 24, 30, 32–33, 43–44, 56–57, 59–60, 577  
equipment service life 380–81, 386, 415  
evaporative air cooler 487  
evaporative air equipment 487  
evaporator 44–45, 47–50, 246, 293, 406, 415, 421, 434, 439, 446, 453, 456–58, 467, 469, 471–72, 475, 476–77, 482, 500–501, 509, 519, 522–23, 525, 526–28, 532–33, 567, 575, 583–84  
exfiltration 74, 146–47, 156, 201  
expansion  
chamber 432, 434, 439, 446–47  
device 47, 49, 456, 457–58, 509, 523, 532  
valve 45, 482–83, 522–26, 538  
extended surface 481, 533, 553, 569  
exterior solar attenuation coefficients 231

## F

fan 1–7, 67, 70, 72, 74–76, 145–46, 158, 192–93, 219, 223, 237, 241–43, 247–49, 291–92, 294–95, 311–12, 316, 318–19, 320, 343–45, 348–49, 354–57, 380, 382, 393–94, 397–98, 400–401, 403–404, 406, 408–409, 416–19, 421–23, 444, 449, 453, 455–57, 461, 473, 481, 490–91, 498, 504, 507, 533, 535, 544, 547, 559, 580, 584, 586, 588–89  
coil units 421–22, 457–58  
laws 349, 354–55, 377  
rooms 408  
selection 355–56, 481  
types 348  
fenestration surfaces 197, 225  
First Law of Thermodynamics 11, 40–46, 67, 69, 72, 519, 567  
fouling factor 520, 570–71, 580, 584  
freeze prevention 407, 448–49  
fuels 5, 291, 380, 385, 406, 541–43, 550  
furnace  
commercial 547–48  
residential 351, 545, 547

## G

green buildings 7

## H

heat balance 220–23, 225, 237, 239–40, 250, 251–52, 292, 472–75  
heat balance (HB) method 222, 292–93  
heat exchanger 1, 49–50, 52, 68, 79, 146, 158, 293, 354, 382, 406–407, 431–34, 443, 444–45, 447, 450–51, 457–58, 459, 467, 469, 471, 476, 488, 497, 499,

500–501, 505–506, 532, 536, 544–48, 550, 552, 559, 565–71, 573, 574–75, 580, 589

heat exchanger design equation 567

heat gain

appliances 219, 223, 242–44, 249–50, 258  
computation 222–23, 233, 237, 250  
computer equipment 247  
copiers 243–44, 247  
fenestration 223, 225–26, 230, 232, 249, 258  
hospital and laboratory equipment 243, 246  
interior surfaces 233, 237  
laser printers 244, 247  
medical equipment 243, 246  
monitors 244, 247, 248  
office equipment 243–45, 248–59  
outdoor air 70, 219–25, 233, 247–49, 258–59, 268  
people 219, 233, 248, 250–51, 253  
walls and roofs 219, 223, 249–51  
heat load 4, 74, 77, 79, 147, 173, 209, 246, 270, 289, 411, 417, 427, 473, 488–89, 523, 567, 587

heat loss

basements 194, 202  
ceiling and roof 202, 205  
concrete slab floor 194–95, 203  
infiltration 204

heat pump types 469

heat pumps 5–6, 42, 49, 291, 380, 382, 421, 453, 458–59, 467–69, 471–72, 476, 510, 548, 554

heat recovery 6, 146, 304, 380, 405, 408, 423, 433–34, 467, 472–76, 479, 497, 499, 500–501, 503–504, 544, 547–48, 554

heat sources, conditioned spaces 233, 497–98, 500–502, 504

heat transfer 15, 36, 38, 43, 47–9, 51–52, 67, 69, 77–78, 82, 141, 145, 158–59, 163, 168, 174, 194, 200–202, 219, 223–25, 233, 237, 241, 249, 251, 258–59, 268, 291–92, 316, 399, 431–33, 447, 450, 459, 469, 471, 477, 482, 486, 499–501, 513, 516, 520–22, 527, 535, 542, 545, 547, 550–51, 559–61, 564, 566–72, 574, 576, 582

heat transfer coefficient 8, 82, 141, 158, 201, 220, 251, 258, 268, 432–43, 505, 520, 526, 528, 560, 565, 568–69, 571, 573–74

heating

coils 318, 433, 443, 449, 463, 481, 486, 487, 498, 559, 567  
electric 553  
values of fuels 542

heating load 8, 72, 136, 145, 191, 193–94, 200–202, 206–208, 219, 252–53, 268, 394–95, 418, 474, 554, 588–89

heating load factor 202, 204

heating load methodology 200

history, ASHRAE 1–5

humidification 2, 67, 88, 136, 145, 147, 475, 490–91, 547–48

humidifiers 154, 245, 380, 402, 490–93, 589  
hydraulic components 432, 436–39  
hydronic systems 8, 364–65, 431–51  
  load control 441–42  
  piping design 440–41, 445

## I

infiltration 67, 74, 136, 145–52, 191, 197,  
  199–202, 217, 219–20, 247–49, 259,  
  268, 291, 297, 304, 462, 547, 555  
  heat loss 204  
infiltration driving force 195  
infrared heaters 544, 548, 549  
insulation 7, 84–86, 145, 154, 158–59, 196,  
  200, 218, 257, 295, 319, 399, 403, 444,  
  448, 463–75, 477, 553, 586, 589  
interior attenuation coefficient 199, 234  
interior solar attenuation coefficient 232,  
  234, 285  
internal energy 12, 14, 22, 36, 38, 40, 43, 220,  
  561  
isentropic exponent 44

## L

leakage area 151–52, 195–96, 206, 215, 513  
LEED 8, 496  
life (of equipment) 389, 584  
lithium bromide-water  
  absorption cycle 532  
  charts 27–28  
load estimating fundamentals 145–54, 156–  
  59, 161, 169, 173

## M

maintenance costs 380–81, 386–87, 389–90,  
  407  
mass, conservation of 13, 67  
mean temperature difference 163, 179, 432–  
  33, 486, 520, 527, 567–68  
metabolic rate 83, 236  
moisture transfer, permeable building materi-  
  als 248  
Mollier diagram 16, 22–23

## N

noise control 358, 408

## O

Orsat 543, 555  
overall heat transfer coefficient 251, 258,  
  432, 520, 527–28, 568, 569

## P

panel heating and cooling 461–65  
payback period 390  
peak exterior irradiance 198, 206  
pipe  
  size data 359, 360  
  sizing calculations 362  
piping 1–3, 158, 219, 292, 311, 318, 362,  
  364, 380, 404, 406–409, 422–23, 431–  
  33, 436–37, 439–41, 443–45, 447–50,  
  457, 459, 461–63, 469, 471, 475, 482–  
  83, 486, 498–99, 516, 544, 550–52, 584  
piping circuits 440, 442, 449  
properties of a substance 13–14

psychrometric chart 2–4, 36–37, 65, 68, 70,  
  74–75, 207, 485, 489

psychrometrics 11, 30,

pump  
  curves 364–65, 436–37  
  laws 364

pumps 3, 5–6, 42, 49, 241, 291–92, 311, 363–  
  64, 380, 382, 398, 404, 407–408, 421,  
  432, 435, 436, 437–38, 441–43, 445,  
  448–49, 453, 456, 458–59, 461, 467–  
  69, 498–99, 510, 532, 548, 554, 580,  
  586, 589

## R

radiant heaters 382, 461, 544, 548  
radiant time series 219, 222, 249–52, 260,  
  264, 265, 268  
radiators 3, 421, 432, 552–54  
reciprocating 5, 363, 407, 453, 467, 472, 477,  
  509–11, 516, 526  
recovery loops 497, 499  
refrigerant  
  aqua-ammonia 26  
  expansion device 47, 522, 532  
  lithium bromide-water 28, 532  
  properties of 527  
refrigeration 3, 4, 7, 11, 22, 44–49, 72, 140,  
  145, 361, 379–80, 394, 399, 403, 406–  
  409, 421, 423, 434, 444–56, 458–59,  
  467, 471, 474, 475, 482, 485, 488–89,  
  509, 513, 515–19, 522, 525, 527, 532–  
  33, 535, 540, 542, 571–72, 582, 584  
  equipment 140, 380, 399, 406–408,  
  467, 509, 527  
  load calculation 483  
relative humidity 31, 83, 86, 88–89, 136, 147,  
  207, 249, 356, 417, 475, 488, 547, 586  
residential 2–6, 8, 81, 84, 89, 136, 146, 148,  
  151, 153, 155, 191–94, 196–97, 199,  
  204, 209, 213, 232, 285, 304, 364–65,  
  394, 403, 410, 415, 431, 440, 441, 443,  
  449, 454, 457–58, 461, 467, 469, 490,  
  515, 542, 544, 547–48, 552, 554  
residential load factor 192  
roof conduction time series (CTS) 254  
R-value 158–59, 161, 169, 202–203

## S

seasonal efficiency 296  
Second Law of Thermodynamics 11, 14, 42–  
  44, 559  
sensible heat factor 74, 193, 206, 259, 457  
sensible heat ratio 74, 76  
sol-air temperature 221–25, 249, 258, 260,  
  263, 276  
solar heat gain coefficient 194–95, 206, 214,  
  223, 226–27, 230–31, 257–58, 277  
solar properties 225–26, 230, 232, 235  
sorption 488–90  
special allowance factors, for nonincan-  
  descent light fixtures 235, 238–39, 257  
specific heat 14, 22, 24, 164, 255, 432–33,  
  450, 471  
steam properties 17–19, 23, 29

surface conductance 158, 161

surface temperature 68, 79, 88, 136, 142,  
  168–69, 201, 203, 220–22, 251, 399,  
  461, 464, 471, 487, 560–61, 563, 574  
sustainability 7–8, 291

systems

  air-and-water 396, 420  
  air-conditioning 7–8, 67, 191, 219, 223,  
  249, 316, 318, 354, 356, 379  
  393–409, 453, 515, 572  
  central air-conditioning 212, 223, 398–  
  99  
  chilled water 8, 140, 444–45, 448–49,  
  469  
  closed water 432–39, 477  
  closed-stationary 41  
  cogeneration 467  
  computer modeling 292  
  design parameters 394–95  
  dual-stream 394, 418  
  dual-temperature 437, 445–46  
  duct 150, 196, 249, 311–13, 315–16,  
  318–19, 349, 403, 417, 449  
  environmental control 1, 81, 394, 399,  
  heat pump 415, 458–59, 467, 469–70  
  586  
  heat recovery 380, 408, 467, 472–73,  
  475, 554  
  heat-cool-off 394  
  low-temperature 419  
  low-temperature heating 443  
  multiple 399  
  option constraints 395  
  primary 405–407, 589  
  reheat 394, 417  
  selection and design 394  
  single-path 72, 74  
  through-the-wall conditioner 456  
  variable air volume 393–94, 418

## T

temperature

  average winter 137  
  balance-point 296–98, 304  
  break-even 473–75  
  calculating surface 169  
  classifications 431  
  dew-point 4, 30, 36, 69, 71, 82, 89, 121,  
  135–36, 223, 233, 249, 259, 291, 296,  
  304, 356, 393–94, 402, 406, 420, 422,  
  434, 445, 461–62, 492  
  dry-bulb 82–83, 89, 121, 136, 406, 420,  
  471, 504, 522, 548  
  operative 82, 86, 143  
  wet-bulb 30–31, 36, 82, 89, 121, 135–  
  36, 191, 193, 223, 304, 457, 474, 485,  
  487, 522, 535  
terminal units 294, 318–19, 380, 418, 422,  
  443–44, 449–50, 552–53  
thermal  
  comfort 81–85, 146, 291, 393  
  components 432–35  
  conductivity 158, 203, 450, 471, 559,  
  560, 582

thermal resistance  
   of plane airspaces 161–63  
 thermal sensation scale 83, 144  
 thermodynamic properties  
   moist air 60  
   applied to HVAC processes 67  
   basic equations 44, 72  
   first law 11, 40–42, 44, 46, 67, 519, 567  
   heat pumps 42, 49  
   properties of moist air 32–36, 60  
   properties of water 16–19  
   reversibility 12–13  
   second law 11, 14, 42–44, 559  
   third law 44  
   zeroth law 13  
 thermodynamics 11, 13, 36, 38, 40, 42, 44, 46, 49, 67, 527, 567  
 thermophysical properties 527, 560, 574  
 total equivalent temperature differential (TETD) method 221  
 transfer function method (TFM) 222

**U**  
 U-factor 158–59, 161, 168–72, 174, 188, 194, 202–203, 207, 218, 223, 226, 231, 251–54, 268  
   determining 159  
 unit heaters 3, 382, 401, 421, 433, 443, 447, 544, 548, 554  
 unitary air conditioners 453–54, 525

**V**  
 valve  
   expansion 45, 482–483, 522–26, 538  
   sizing 442  
 variable air volume 5–6, 154, 294, 394, 398, 401, 417  
 ventilation 2, 67, 73, 136, 145–48, 151, 153–55, 157, 191, 193–94, 196, 199–201, 208, 217, 219, 259, 420, 487, 494, 496, 498  
 ventilation and infiltration air 145, 247

**W**  
 wall conductance time series (CTS) 252  
 water coil 382, 406, 419–20, 444, 449, 482, 486–87, 491–92, 499, 500, 504  
 water system, power and energy of 398  
 wet-bulb temperature 30–31, 36, 82, 89, 121, 135–36, 475, 487, 504  
 wind chill temperatures 140, 144  
 windows 1, 74, 88, 145–48, 151, 159, 161, 169, 171, 194, 197, 199, 201, 205, 207–208, 219–20, 222, 249–51, 257, 259, 265, 298, 408, 421, 471, 475, 552, 586, 589  
 winter average temperatures 137