

(This foreword is provided for information only and is not part of the draft addendum.)

FOREWORD

Draft Addendum 90.1aa –Publication Draft. Connected load is not always the sizing method used in electrical design. Having the voltage drop sizing criteria different from the other aspects of the sizing is inappropriate.

Addendum aa

8.2 Mandatory Provisions

8.2.1 Voltage Drop

8.2.1.1 Feeders. *Feeder conductors* shall be sized for a maximum *voltage drop* of 2% at design load.

8.2.1.2 Branch Circuits. *Branch circuit* conductors shall be sized for a maximum *voltage drop* of 3% at design load.