

**ERRATA SHEET FOR
ANSI/ASHRAE/IES STANDARD 100-2015
Energy Efficiency in Existing Buildings**

February 12, 2018

The corrections listed in this errata sheet apply to ANSI/ASHRAE/IES Standard 100-2015. The first printing is identified on the outside back cover as “Product code: 86298 2/15”.

Page Erratum

- 35** **Normative Appendix C, Form E – End Use Analysis Requirements Level 2.** In the second part of Form E make the following corrections to the form.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

Fuel or Other End Uses (List base-case energy-use estimates of all ~~identified EEMs~~ end uses that comprise >5% of annual site use.)

- 45** **Informative Appendix E Energy Efficiency Measures.** Make the following corrections to Section E5.2.8.
(Note: Additions are shown in underline and deletions are shown in ~~strikethrough~~.)

E5.2.8 Install two-speed, mechanical unloading or VFD on c~~C~~ompressor motors.