

**ERRATA SHEET FOR THE USER'S MANUAL TO
ANSI/ASHRAE STANDARD 62.1-2004
VENTILATION FOR ACCEPTABLE INDOOR AIR QUALITY**

June 17, 2008

The corrections listed in this errata sheet apply to all copies of ANSI/ASHRAE Standard 62.1-2004 User's Manual. The shaded item has been added since the previously published errata sheet dated 5/11/2007 was distributed.

NOTICE: ASHRAE now has a list server for Standing Standards Project Committee 62.1 (SSPC 62.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard is available. To sign up for the list server please visit **Standards List Servers** on the Standards and Codes section of the ASHRAE website at <http://www.ashrae.org/publications/detail/15620>.

Page Erratum

5-4 Example 5-B Natural Ventilation Prescriptive Requirements.

1. Make the following changes to the diagram:

Change “3 m² typ. 16” to “3 m² typ. 12” and “1.5 m²” to “1.5 m² typ. 12”.

2. Make the following corrections to the data table:

(Note: Additions are shown in underline and deletions are shown in ~~strike through~~.)

| Space No. | Width (m) | Depth (m) | Floor Area (m ²) | Gross Window Area (m ²) | Direct Opening Area (m ²) | Direct Opening (%) | Meets Direct Criterion? | Indirect Opening Area (m ²) | Indirect Opening Area (%) | Meets Indirect Criterion? | Within 8 m of Opening Wall? | Meets Prescriptive? |
|-----------|-----------|-----------|------------------------------|-------------------------------------|---------------------------------------|--------------------|-------------------------|---|---------------------------|---------------------------|-----------------------------|---------------------|
| 1 | 8 | 8 | 64676 | 24 | 4.8 | 7.5 | Y | - | - | N | Y | Y |
| 2 | 4 | 4 | 16169 | 6 | 2.4 | 15 | Y | - | - | N | Y | Y |
| 3 | 4 | 4 | 16169 | 6 | 2.4 | 15 | Y | - | - | N | Y | Y |
| 4 | 5 | 4 | 20208 | 4.5 | 1.8 | 9 | Y | - | - | N | Y | Y |
| 5 | 5 | 4 | 20208 | 1.5 | 0.6 | 3 | N | - | - | N | Y | N |
| 6 | 6 | 8 | 48520 | 12 | 4.8 | 10 | Y | - | - | N | Y | Y |
| 7 | 12 | 4 | 48507 | - | - | - | N | <u>332</u> | 6.3 | N | N | N |
| 8 | 4 | 4 | 16169 | - | - | - | N | <u>332</u> | 18.8 | Y | N | N |
| 9 | 2 | 4 | 878 | - | - | - | N | <u>332</u> | 37.5 | Y | Y | Y |

2. Correct the following notes as shown:

Direct opening area is the area of the operable opening (20% of the gross window area for 3 m² windows, 40% of the gross window area for the 1.5 m² windows) direct from the room to the outdoors.

Direct opening in percentage is the direct opening ~~area~~ divided by the floor area.

5-28 **Figure 5-U – Finned Tube Coil Cleanability.** Change the maximum pressure drop SI units from “(187 Pa @ 254 m/s)” to “(187 Pa @ 2.54 m/s)”.