

ASHRAE Technical FAQ

ID 25

Question How do I satisfy the [ASHRAE Standard 15-2016](#) Table 1 value when the refrigerant I want to use is listed in [ASHRAE Standard 34-2016](#) but not in Table 1 of [ASHRAE Standard 15-2016](#)?

The current version, [ASHRAE Standard 15-2016](#), eliminated Table 1 and references [Standard 34](#), Designation and Safety Classification of Refrigerants, which lists the Refrigerant Concentration Limits (RCL) for all refrigerants in Table 1 and 2. Informative Appendix G of [ASHRAE Standard 34-2016](#) provides information on calculating RCLs for blends that may not be listed in Tables 1 or 2.

Answer

[ASHRAE Standard 15-2016](#) and [ASHRAE Standard 34-2016](#) are now packaged and sold together.

Copies of the standards and latest addenda may be purchased and downloaded on-line at our website, www.ashrae.org or by calling 1-800-527-4723 in the USA and Canada or 1-404-636-8400 worldwide. Addenda to the standards may be downloaded for free.

[ASHRAE Standard 15-2016](#), plus [ASHRAE BOD approved addenda](#).

ASHRAE Pubs [ASHRAE Standard 34-2016](#), plus [ASHRAE BOD approved addenda](#).

[User's Manual for ASHRAE Standard 15-2001](#), Safety Standard for Refrigeration Systems

Topic References Refrigerants, Safety Code of Refrigerants

	Cognizant ASHRAE Committees	Refer to Organization
1	TC 10.1	
2	TC 9.1	
3	SSPC 15	
4	SSPC 34	
5		